


## LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 96.38 lm/W			
MODEL		I <sub>max</sub> (cd)	1964	S/MH(C0/180)	0.96
NOMINAL POWER(W)	17.77	LOR(%)	100.0	S/MH(C90/270)	0.41
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	1685.1	η UP,DN(C0-180)	0.7,72.7
NOMINAL FLUX(lm)	1685.05	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.2,26.5
LAMPS INSIDE	1	η up(%)	0.9	CIBSE SHR NOM	0.75
TEST VOLTAGE(V)	120	η down(%)	99.1	CIBSE SHR MAX	0.80

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

γ Range: 0 - 110DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:


$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	$\%lum, lamp$
10	784.8	836.3	967.2	917.2	578.3	397.8	427.1	618.1	0- 10	64.53	64.53	3.83,3.83
20	1024	839.8	1293	1447	526.3	165.9	98.42	666.9	10- 20	207.2	271.7	16.1,16.1
30	1486	658.9	1192	1433	411.9	27.13	33.44	855.6	20- 30	359.0	630.7	37.4,37.4
40	1516	425.0	676.7	842.2	109.0	16.28	22.97	793.7	30- 40	413.0	1044	61.9,61.9
50	940.7	241.9	393.2	432.1	18.13	8.371	15.05	425.6	40- 50	316.4	1360	80.7,80.7
60	444.8	101.6	178.1	188.9	11.80	2.476	7.647	208.7	50- 60	187.5	1548	91.8,91.8
70	250.6	31.75	28.16	21.96	7.343	0.0118	4.341	83.59	60- 70	84.67	1632	96.9,96.9
80	28.12	26.04	20.35	13.12	4.099	0.0010	0.3567	16.55	70- 80	25.78	1658	98.4,98.4
90	20.09	21.07	13.74	8.708	0.0263	0.0016	0.0006	11.66	80- 90	12.59	1671	99.1,99.1
100	14.16	15.47	9.709	5.619	0.0264	0.0048	0.0009	7.450	90-100	8.880	1680	99.7,99.7
110	10.82	8.000	5.783	2.203	0.0728	0.0184	0.0170	3.746	100-110	5.357	1685	100,100
120	0	0	0	0	0	0	0	0	110-120	0.1910	1685	100,100
130	0	0	0	0	0	0	0	0	120-130	0	1685	100,100
140	0	0	0	0	0	0	0	0	130-140	0	1685	100,100
150	0	0	0	0	0	0	0	0	140-150	0	1685	100,100
160	0	0	0	0	0	0	0	0	150-160	0	1685	100,100
170	0	0	0	0	0	0	0	0	160-170	0	1685	100,100
180	0	0	0	0	0	0	0	0	170-180	0	1685	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

$\gamma$  Range: 0 - 110DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

## LUMINANCE LIMITATION CURVES

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	756	498
80	450	326
75	918	259
70	2035	229
65	2406	320
60	2471	989
55	2949	1530
50	4065	1699
45	4909	1905


C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:DAMIN  
 Test Date:30 October 2021

γ Range: 0 - 110DEG  
 γ Interval: 1.0DEG  
 Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
 Humidity:65.0%  
 Test Distance:1.819m [K=1.0000]  
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:DAMIN  
 Test Date:30 October 2021

γ Range: 0 - 110DEG  
 γ Interval: 1.0DEG  
 Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
 Humidity:65.0%  
 Test Distance:1.819m [K=1.0000]  
 Remarks:

## WEC AND CCEC

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm								
NAME: 感应灯			TYPE:			WEIGHT:		
SPEC.:			DIM.:			SERIAL No.:1		
MFR.: EVERFINE			SUR.:0.6*0.6M			Shielding Angle:		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.244	.139	.044	.237	.135	.043	.223	.128	.041	.211	.122	.039	.199	.116	.037	
2.0	.235	.129	.040	.229	.126	.039	.218	.121	.038	.207	.116	.036	.197	.111	.035	
3.0	.224	.119	.036	.218	.117	.035	.208	.113	.034	.199	.109	.033	.190	.105	.033	
4.0	.211	.110	.032	.207	.108	.032	.197	.105	.031	.189	.102	.031	.181	.099	.030	
5.0	.199	.102	.029	.195	.100	.029	.187	.097	.029	.180	.095	.028	.173	.092	.028	
6.0	.188	.094	.027	.184	.093	.027	.177	.091	.026	.170	.089	.026	.164	.086	.026	
7.0	.178	.088	.025	.174	.087	.025	.168	.085	.024	.162	.083	.024	.156	.081	.024	
8.0	.168	.082	.023	.165	.081	.023	.159	.079	.023	.154	.078	.022	.149	.076	.022	
9.0	.159	.077	.021	.156	.076	.021	.151	.075	.021	.146	.073	.021	.142	.072	.021	
10.0	.151	.072	.020	.148	.072	.020	.144	.070	.020	.139	.069	.020	.135	.068	.019	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.197	.197	.197	.168	.168	.168	.115	.115	.115	.066	.066	.066	.021	.021	.021	
1.0	.182	.163	.146	.156	.140	.126	.107	.096	.087	.061	.056	.051	.020	.018	.016	
2.0	.171	.139	.111	.147	.119	.096	.101	.083	.067	.058	.048	.039	.019	.016	.013	
3.0	.162	.121	.088	.139	.104	.076	.095	.072	.053	.055	.042	.031	.018	.014	.010	
4.0	.154	.107	.071	.132	.092	.061	.091	.064	.043	.053	.038	.026	.017	.012	.008	
5.0	.147	.096	.058	.126	.083	.051	.087	.058	.036	.050	.034	.021	.016	.011	.007	
6.0	.140	.087	.050	.121	.076	.043	.083	.053	.031	.048	.031	.018	.016	.010	.006	
7.0	.134	.080	.043	.115	.070	.037	.080	.049	.026	.046	.029	.016	.015	.009	.005	
8.0	.128	.075	.038	.111	.065	.033	.076	.045	.023	.044	.027	.014	.014	.009	.005	
9.0	.123	.070	.034	.106	.061	.029	.073	.043	.021	.043	.025	.012	.014	.008	.004	
10.0	.118	.065	.031	.102	.057	.027	.071	.040	.019	.041	.024	.011	.013	.008	.004	

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

γ Range: 0 - 110DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

## UGR(Unified Glare Rating) Table

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm												
NAME: 感应灯					TYPE:			WEIGHT:				
SPEC.:					DIM.:			SERIAL No.:1				
MFR.: EVERFINE					SUR.:0.6*0.6M			Shielding Angle:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3		
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3		
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2		
Room dimensions		Viewed crosswise				Viewed endwise						
x = 2H y = 2H		15.0	16.3	15.3	16.6	16.8	9.6	10.9	9.9	11.1	11.3	
		3H	16.1	17.3	16.4	17.5	17.7	9.6	10.8	9.9	11.0	11.2
		4H	16.2	17.3	16.5	17.6	17.9	9.6	10.7	9.9	11.0	11.2
		6H	16.2	17.3	16.5	17.5	17.8	9.7	10.7	10.0	11.0	11.3
		8H	16.2	17.2	16.5	17.5	17.8	9.7	10.7	10.1	11.0	11.3
		12H	16.2	17.2	16.5	17.4	17.8	9.8	10.8	10.2	11.1	11.4
4H		2H	14.8	15.9	15.1	16.2	16.4	9.7	10.8	10.0	11.1	11.3
		3H	15.8	16.8	16.2	17.1	17.4	9.7	10.7	10.1	11.0	11.3
		4H	16.0	16.9	16.4	17.2	17.6	9.8	10.7	10.2	11.0	11.3
		6H	16.1	16.8	16.5	17.2	17.6	10.0	10.8	10.4	11.1	11.5
		8H	16.1	16.8	16.5	17.2	17.6	10.1	10.9	10.6	11.2	11.6
		12H	16.1	16.8	16.5	17.2	17.6	10.3	11.0	10.8	11.4	11.8
8H		4H	15.9	16.6	16.3	17.0	17.4	9.8	10.6	10.3	10.9	11.3
		6H	16.0	16.6	16.4	17.0	17.4	10.2	10.8	10.6	11.2	11.6
		8H	16.0	16.6	16.5	17.0	17.5	10.5	11.0	10.9	11.4	11.9
		12H	16.1	16.6	16.6	17.0	17.5	10.8	11.3	11.3	11.7	12.2
12H		4H	15.9	16.5	16.3	16.9	17.3	9.8	10.5	10.3	10.9	11.3
		6H	16.0	16.5	16.4	16.9	17.4	10.3	10.8	10.7	11.2	11.7
		8H	16.0	16.5	16.5	16.9	17.4	10.6	11.0	11.1	11.5	12.0
Variations with the observer position at spacings:												
S = 1.0H		+ 1.6 / - 0.8				+ 2.0 / - 1.9						
1.5H		+ 2.7 / - 3.0				+ 2.7 / - 3.7						
2.0H		+ 4.3 / - 5.2				+ 3.5 / - 3.4						

CIE Pub.117, 1685 lm Total Lamp Luminous Flux Correct ( $8\log(F/F_0) = 1.8$ )

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

$\gamma$  Range: 0 - 110DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

### UTILIZATION FACTORS TABLE

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	67	57	52	67	57	51	66	57	51	46
0.80	77	68	62	76	67	62	75	67	61	55
1.00	85	76	70	84	76	70	82	76	70	64
1.25	92	83	78	90	83	77	88	81	76	70
1.50	96	88	83	94	87	82	92	86	81	75
2.00	101	95	90	99	93	89	96	91	87	81
2.50	104	98	93	102	97	92	98	94	90	83
3.00	106	101	97	104	100	96	101	97	94	86
4.00	109	105	101	107	103	100	103	100	97	89
5.00	111	107	104	109	105	103	104	102	99	91
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

$\gamma$  Range: 0 - 110DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

# ISOCANDELA DIAGRAM

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:




C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

γ Range: 0 - 110DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

### AAI Figure

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:

Flux out:271.7 lm




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: DAMIN  
 Test Date: 30 October 2021

γ Range: 0 - 110DEG  
 γ Interval: 1.0DEG  
 Test System: EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
 Humidity: 65.0%  
 Test Distance: 1.819m [K=1.0000]  
 Remarks:

ISOLUX DIAGRAM

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

γ Range: 0 - 110DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

### LED Avg.L Report

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	1234
L_0~180(75)av	490
L_0~180(85)av	408
L_90~270(65)av	179
L_90~270(75)av	142
L_90~270(85)av	249
L_45(65)av	406
L_45(75)av	164
L_45(85)av	392

Standard: GB/T 29293-2012

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:DAMIN  
Test Date:30 October 2021

γ Range: 0 - 110DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
Humidity:65.0%  
Test Distance:1.819m [K=1.0000]  
Remarks:

# Planar Illuminance Curve



C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: DAMIN  
 Test Date: 30 October 2021

$\gamma$  Range: 0 - 110DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System: EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6  
 Humidity: 65.0%  
 Test Distance: 1.819m [K=1.0000]  
 Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.46V I:0.1588A P:17.483W PF:0.9142 Freq:59.97Hz Lamp Flux:1685.05x1 lm		
NAME: 感应灯	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: EVERFINE	SUR.:0.6*0.6M	Shielding Angle:

Table--1

UNIT: cd

C(DEC) γ (DEC)	0	30	60	90	120	150	180	210	240	270	300	330						
0	658	649	648	647	654	660	658	649	648	647	654	660						
5	752	768	770	773	739	655	580	503	514	582	656	710						
10	785	801	872	967	1010	824	578	432	364	427	563	673						
15	837	814	901	1177	1372	1017	572	391	213	217	471	697						
20	1024	834	846	1293	1737	1157	526	276	55.7	98.4	450	884						
25	1209	808	731	1323	1959	1150	465	129	32.1	47.4	452	1104						
30	1486	705	612	1192	1846	1019	412	28.6	25.7	33.4	435	1276						
35	1595	569	494	970	1541	799	273	22.1	20.2	27.8	414	1318						
40	1516	470	380	677	1120	565	109	17.0	15.5	23.0	390	1198						
45	1250	412	238	485	731	442	25.2	12.0	11.6	18.9	280	978						
50	941	365	119	393	490	374	18.1	8.45	8.29	15.1	171	680						
55	609	270	48.7	316	388	244	14.7	6.49	3.01	10.8	49.5	490						
60	445	166	37.2	178	289	89.0	11.8	4.92	0.03	7.65	22.6	395						
65	366	58.1	33.2	48.7	118	21.6	9.38	2.53	0.00	5.93	19.5	281						
70	251	33.8	29.7	28.2	27.1	16.8	7.34	0.02	0.00	4.34	16.6	151						
75	85.5	30.8	26.6	24.1	18.7	13.4	5.71	0.00	0.00	2.42	13.9	30.3						
80	28.1	28.0	24.1	20.4	15.6	10.7	4.10	0.00	0.00	0.36	11.4	21.7						
85	23.7	25.1	22.1	15.6	12.9	8.40	1.89	0.00	0.00	0.01	9.20	18.7						
90	20.1	22.1	20.1	13.7	10.7	6.75	0.03	0.00	0.00	0.00	7.36	16.0						
95	16.4	17.5	17.7	12.0	8.96	5.38	0.01	0.00	0.00	0.00	5.64	13.4						
100	14.2	15.7	15.2	9.71	7.62	3.62	0.03	0.01	0.00	0.00	3.65	11.2						
105	12.5	12.7	8.00	7.87	6.24	0.73	0.05	0.02	0.00	0.01	0.94	9.38						
110	10.8	9.11	6.89	5.78	4.35	0.06	0.07	0.03	0.00	0.02	0.03	7.46						
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						

C Range: 0 - 360DEG

C Interval: 30.0DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:DAMIN

Test Date:30 October 2021

γ Range: 0 - 110DEG

γ Interval: 1.0DEG

Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.404.6

Humidity:65.0%

Test Distance:1.819m [K=1.0000]

Remarks: